



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

<b>System Designation:</b>	PYRO-200 HFC-227ea Fire Extinguishing Systems
<b>Flow Calculation Software</b>	PYR Flow Calculation Software v4.00 (HFC-227ea)
<b>Design, Installation, Operation, Maintenance, Software, and Owner's Manuals:</b>	Pyronics HFC-227ea Fire Suppression System Design, Installation and Engineering Manual for PYRO-200 System, Part Number: PYR-INT-FS-HFC-MANUAL, Revision 0 Pyronics HFC-227ea/FK-5-1-12 Fire Suppression Systems Owner's Manual for Pyro-200/Pyro-5112 System, Part Number: PYR-INT-FS-HFC-FK-OMANUAL, Rev. 0

*Approval Guide* Listing Category: Fixed Extinguishing Systems, Clean Agent Extinguishing Systems

Adkinns Inc.  
5062 Commercial Circle  
Concord CA, 94520  
USA

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):


<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i> 5600	August 2021

FM Approvals Listing Class: 5612

Original Approval Project Identification: PR462879  
Subsequent Revisions: None

Approval Granted: 29 June 2022

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

  
James E. Marquedant  
VP, Manager - Electrical Systems  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA

29 June 2022

\_\_\_\_\_  
Date



*Member of the FM Global Group*